

ORIGINAL



0000102649

Steve Wene, No. 019630
MOYES SELLERS & SIMS LTD.
1850 N. Central Avenue, Suite 1100
Phoenix, Arizona 85004
(602)-604-2189
swene@lawms.com
Attorneys for Valle Verde Water Company

RECEIVED

2001 SEP 11 P 1:07

ARIZONA CORPORATION COMMISSION
DOCKET CONTROL

BEFORE THE ARIZONA CORPORATION COMMISSION

COMMISSIONERS

KRISTIN K. MAYES, CHAIRMAN
GARY PIERCE
PAUL NEWMAN
SANDRA D. KENNEDY
BOB STUMP

Arizona Corporation Commission

DOCKETED

SEP 12 / 2001

DOCKETED BY

APPLICATION OF ESTATE OF
WILLIAM F. RANDALL DBA VALLE
VERDE WATER COMPANY FOR AN
INCREASE IN ITS WATER RATES

Docket No. W-01431A-09-0360

**RESPONSE TO LETTER OF
DEFICIENCY**

Valle Verde Water Company ("Company"), hereby responds to Arizona
Corporation Commission Staff's Letter of Deficiency as follows:

1. The information on page 1 for PWS #12-025 of Exhibit 5 is incomplete. Please
provide complete information.


RESPONSE: See revised Exhibit 5 set forth in Attachment 1.

2. The information on page 1 for PWS #12-009 of Exhibit 5 is incomplete. Please
provide complete information.

RESPONSE: See revised Exhibit 5 set forth in Attachment 2.

1 RESPECTFULLY SUBMITTED this 11th day of September, 2009.

2 **Moyes Sellers & Sims**

3
4 
5 Steve Wene
6 Attorneys for Valle Verde Water Company


7
8 Original and 15 copies of the foregoing
9 filed this 11th day of September, 2009, with:

10 Docket Control
11 Arizona Corporation Commission
12 1200 West Washington
13 Phoenix, Arizona 85007

14 Copy of the foregoing mailed this
15 11th day of September, 2009, to:

16 Maureen Scott
17 Legal Division
18 Arizona Corporation Commission
19 1200 W. Washington Street
20 Phoenix, Arizona 85007
21 mscott@azcc.gov

22 Pedro Chaves
23 Utilities Division
24 Arizona Corporation Commission
25 1200 West Washington Street
26 Phoenix, Arizona 85007
27 pchaves@azcc.gov
28

29 

ATTACHMENT 1

COMPANY NAME Valle Verde Water Company	Test Year Ended: 31-Dec-08
Name of System:	ADEQ Public Water System Number: 12-025

WATER COMPANY PLANT DESCRIPTION

WELLS

ADWR ID Number*	Pump Horsepower	Pump Yield (gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Meter Size (inches)	Year Drilled
55-500951	50	350	400	16	6	1982
55-502001	40	600	450	16	6	1982
55-582348	N/A	300	290	12	3	2001

* Arizona Department of Water Resources Identification Number

OTHER WATER SOURCES

Name or Description	Capacity (gpm)	Gallons Purchased or Obtained (in thousands)
None		

BOOSTER PUMPS		FIRE HYDRANTS	
Horsepower	Quantity	Quantity Standard	Quantity Other
15	2	32	
30	3		
25	2		
50	1		
100	2		

STORAGE TANKS		PRESSURE TANKS	
Capacity	Quantity	Capacity	Quantity
800,000	1	5,000	2
200,000	1	10,000	1

Company Name: Valle Verde Water Company	Test Year Ended: 31-Dec-08
ADEQ PWS 12-025	

WATER COMPANY PLANT DESCRIPTION CONTINUED

MAINS			CUSTOMER METERS	
Size (in inches)	Material	Length (in feet)	Size (in inches)	Quantity
2			5/8 x 3/4	68
3			3/4	4
4			1	9
5			1 1/2	
6			2	8
8			Comp. 3	2
10			Turbo 3	
12			Comp. 4	1
			Turbo 4	
Amounts included on page for system 12-009			Comp. 6	
			Turbo 6	

For the following three items, please list the utility owned assets in each category.

TREATMENT EQUIPMENT:

Four inch PVC Chlorinator using Chlorine Tablets

STRUCTURES:

OTHER:

ATTACHMENT 2

COMPANY NAME Valle Verde Water Company	Test Year Ended: 31-Dec-08
Name of System:	ADEQ Public Water System Number: 12-009

WATER COMPANY PLANT DESCRIPTION

WELLS

ADWR ID Number*	Pump Horsepower	Pump Yield (gpm)	Casing Depth (Feet)	Casing Diameter (Inches)	Meter Size (inches)	Year Drilled
55-617053	30	200	105	12	4	1954
55-617054	30	350	260	16	6	1972
55-617055	15	130	220	12	3	1971
55-513789	10	70	203	12	3	1987
55-801847	30	400	93	10	4	1933

* Arizona Department of Water Resources Identification Number

OTHER WATER SOURCES

Name or Description	Capacity (gpm)	Gallons Purchased or Obtained (in thousands)
City of Nogales	200	75,309

BOOSTER PUMPS		FIRE HYDRANTS	
Horsepower	Quantity	Quantity Standard	Quantity Other
N/A		13	

STORAGE TANKS		PRESSURE TANKS	
Capacity	Quantity	Capacity	Quantity
N/A		7,000	1
		3,000	2
		7,500	1
		10,000	1

Company Name: Valle Verde Water Company	Test Year Ended: 31-Dec-08
ADEQ PWS 12-009	

MAINS*

Size (in inches)	Material	Length (in feet)
2	PVC	8,397
3	AC	920
4	PVC	16,560
5		
6	PVC	19,818
8	PVC	3,220
10		
12	PVC	400
16	PVC	2,175
18	PVC	1,070
3	Steel	1,300
4	AC	8,299

CUSTOMER METERS

Size (in inches)	Quantity
5/8 x 3/4	316
3/4	404
1	38
1 1/2	3
2	12
Comp. 3	3
Turbo 3	
Comp. 4	
Turbo 4	
Comp. 6	
Turbo 6	

For the following three items, please list the utility owned assets in each category.

TREATMENT EQUIPMENT:

Four inch PVC Chlorinator using Chlorine Tablets

STRUCTURES:

Office at 12 Garden View in Nogales

12 x 10 foot building at Well #2

OTHER:

* Mains length amounts include both system 12-009 and 12-025, no separate detail available